



Job Name: Sample

Job Number: Sample

Location: Sample

Survey Date:

Surveyor: ras

Area (metres²): 10000

Specified Tolerances:

Overall:

F_F	F_L
50	50

Minimum local:

F_F	F_L
50	50

Surface Results:

Overall:

F_F	F_L
15.42	13.93

Section	Area (m ²)	F _F	F _L	Combined values		
				Finished area	F _F	F _L
Section 1	10000	15.42	13.93	10000	15.42	13.93

Section 1

Measured F_F = 15.42 [14.81 - 16.02]		Specified F _F : 50	Min Local F _F : 50	
Measured F_L = 13.93 [13.34 - 14.52]		Specified F _L : 50	Min Local F _L : 50	
Test Sample	F _F	F _L	Length (m)	Readings
Run 1	14.73 [17.01 - 12.46]	13.00 [15.15 - 10.85]	19.8	66
Run 2	14.99 [17.31 - 12.67]	12.42 [14.47 - 10.36]	19.8	66
Run 3	14.90 [17.20 - 12.60]	12.61 [14.70 - 10.52]	19.8	66
Run 4	15.25 [17.61 - 12.89]	12.68 [14.78 - 10.58]	19.8	66
Run 5	15.20 [17.55 - 12.85]	12.14 [14.15 - 10.13]	19.8	66
Run 6	15.73 [18.16 - 13.30]	15.75 [18.36 - 13.14]	19.8	66
Run 7	15.66 [18.08 - 13.24]	15.23 [17.75 - 12.71]	19.8	66
Run 8	15.86 [18.30 - 13.41]	17.03 [19.85 - 14.21]	19.8	66
Run 9	15.91 [18.37 - 13.45]	16.11 [18.78 - 13.44]	19.8	66
Run 10	16.14 [18.63 - 13.64]	15.41 [17.96 - 12.86]	19.8	66